

EU DECLARATION OF CONFORMITY

No. 1A-EU-52/23-03

In accordance with EU directive 2014/35/EU as amended

We, **KOPOS KOLÍN a. s.**
 Havlíčkova 432
 280 02 Kolín
 Czech Republic
 IČ: 61672971
 DIČ: CZ61672971

declare under our sole responsibility that

the product/type: **Wiring double-phase injection boxes for mouting under plaster
 KP 68/D, KPR 68/D, KP 68/D HF, KPR 68/D HF (see Annex)**

manufacturer: **KOPOS KOLÍN a.s., Havlíčkova 432, Kolín IV, 280 02 Kolín, Czech Republic**

object of the declaration: Boxes and covers used for electric accessories for house and other similar fixed electrical installations.
 Temperature resistance of the boxes: -5 °C to + 60 °C.
 Protection against solid objects: IP 30 is fulfilled if accessories with protection IP 30 or higher are used.
 The glow-wire test meets: 850°C.
 The needle burner test was conducted in accordance with ČSN EN 60695-11-5 with satisfactory result.

The object of the declaration described above is in conformity with the relevant Union harmonisation legislation, other legislation and regulations:

| Regulations Of the European Union | Government Regulations | Standards | Certificates and Test Reports | Other technical specification/tested product |
|-----------------------------------|---|--|--|--|
| 2014/35/EU - LVD | Law No. 90/2016 Coll. as amended Government Regulation No. 118/2016 Coll. as amended | ČSN EN IEC 60670-1 ed.2:21 including amendments ČSN EN 60670-1:05 including amendments (EN 60670-1:05 including amendments) | Test Report No. 230020-01/01 of 31.01.2023 Issued by: Electrotechnical Testing Institute, Pod Lisem 129, 171 02 Prague 71, Czech Republic | KP 68/D KPR 68/D KP 68/D HF KPR 68/D HF |
| 2014/35/EU - LVD | Law No. 90/2016 Coll. as amended Government Regulation No. 118/2016 Coll. as amended | ČSN EN 60670-1:05 including amendments (EN 60670-1:05 including amendments) ČSN EN 60670-22:07 including amendments (EN 60670-22:06 including amendments) | Test Report No. 913245-01/01 of 30.1.2020 Issued by: Electrotechnical Testing Institute, Pod Lisem 129, 171 02 Prague 71, Czech Republic | Halogen-free boxes KP 68/D HF KPR 68/D HF |
| 2014/35/EU - LVD | Law No. 90/2016 Coll. as amended Government Regulation No. | ČSN EN 60670-1:05 including amendments (EN 60670-1:05 including amendments) | Test Report No. 911899-01/01 of 13.11.2019 Issued by: | Wiring double-phase injection boxes for mouting under plaster KP 68/D |

| | | | | |
|------------------------------|---------------------------|--|---|--|
| | 118/2016 Coll. as amended | | Electrotechnical Testing Institute, Pod Lisem 129, 171 02 Prague 71, Czech Republic | KPR 68/D |
| | | | | Halogen-free (HF) according to documents from the supplier |
| Regulation 1907/2006 - REACH | | | | Safety data sheets for used materials |

By fulfilling the conditions in accordance with these regulations was placed on the product CE marking.

Conformity assessment module: **MODUL A: Internal production control**


Technical documentation of products:

- assembly instructions
- Datasheet
- Catalog for products freely available on <http://www.kopos.com/en/catalogy>
- Internal documents

KOPOS KOLÍN a.s. company is certificated according to the standard ISO 9001:2015, ISO 14001:2015 and ISO 50001:2018 and according to the National program „Safety Enterprise“.

Signed on behalf of KOPOS KOLÍN a.s.

Place of issue: Kolín, Czech Republic
 Date of issue: 23.03.2023



Ing. Jana Dejmková
 quality director

KOPOS KOLÍN a.s. 
 Havlíčkova 432, 280 02 Kolín
 IČ: 616 72 971 DIČ: CZ61672971
 tel: 321 730 111 www.kopos.cz

Enclosure No. 1 to EU Conformity Declaration No. 1A-EU-52/23-03**Wiring double-phase injection boxes for mouting under plaster****Type**

KP 68/D Wiring box

KPR 68/D Wiring box


Wiring double-phase injection boxes for mouting under plaster halogen-free**Type**

KP 68/D HF Wiring box

KPR 68/D HF Wiring box

Accessories

NR 5x5 Extension frame

KOPOS KOLÍN a.s. 
Havlíčková 432, 280 02 Kolín
IČ: 616 72 971 DIČ: CZ61672971
tel: 321 730 111 www.kopos.cz

