

EU DECLARATION OF CONFORMITY

No. 3B-EU-29/26-07

In accordance with EU directive 2014/35/EU as amended

We, **KOPOS KOLÍN a. s.**
Havlíčkova 432
280 02 Kolín
Czech Republic
IČ: 61672971
DIČ: CZ61672971

declare under our sole responsibility that

the product/type: **Divided cable duct "KOPOHALF" and accessories**
cable duct: 06058/2, 06083/2, 06110/2, 06120/2, 06160/2 and accessories

manufacturer: **KOPOS KOLÍN a.s. Havlíčkova 432, Kolín IV, 280 02 Kolín, Czech Republic**

object of the declaration: A system of divided cable ducts is suitable mainly for a protection of underground cable laying-out of the energy and communication lines. Another possible application is a protection of already installed underground cables. The protectors consist of two identical parts. When installing, the cables are put in the bottom part and then the top part is snapped to the bottom one.

Material: HDPE
Installation temperature: -25°C to +90°C
Operating temperature: -55°C to +90°C
Resistance to spread of flame: flame
Resistance to compression: 06058/2 - 06120/2 – 450 N/20cm
06160/2 - 750 N/20cm
Impact resistance: normal (code N)
Resistance to external influences: IP30
Recycled materials can be used for the production of the divided cable duct

The object of the declaration described above is in conformity with the relevant Union harmonisation legislation, other legislation and regulations:

Regulations Of the European Union	Government Regulations	Standards	Certificates and Test Reports	Other technical specification
		EN 15804+A2:2022 ISO 14025:2006	Environmental Product Declaration No: EPD-Sk10--05-26 of 26.06.2026. Verification EPD: Independent verification of declarations and data in accordance with ISO 14025:2006 was carried out externally by a third party. Verifier: prof. Ing. Vladimír Kočí, PhD, MBA www.lca.cz	For KOPOHALF divided cable duct
2014/35/EU - LVD	Law No. 90/2016 Coll. as amended Government Regulation No. 118/2016 Coll. as amended	ČSN EN 50626-1:2024 ČSN EN ISO 9969:2016	Test Report No. 252156-01/01 of 31.10.2025 Issued by: Electrotechnical Testing Institute, Pod Lisem 129, 171 02 Prague 71, Czech Republic	06110/2 06160/2 General: recycled materials can be used for the production of the divided cable duct

2014/35/EU - LVD	Law No. 90/2016 Coll. as amended Government Regulation No. 118/2016 Coll. as amended	ČSN EN 61386-1 ed. 2:09 čl. 10.3, 12.4, 12	Test Report No. 212630-01/01 of 26.11.2021 Issued by: Electrotechnical Testing Institute, Pod Lisem 129, 171 02 Prague 71, Czech Republic	06110/2, 06160/2 Installation temperature -25°C to +90°C Operating temperature -55°C to +90°C
		ČSN EN 61386-1 ed. 2:09 ČSN EN 61386- 24:11	Test Report No. 603670-01/01 of 27.9.2016 Issued by: Electrotechnical Testing Institute, Pod Lisem 129, 171 02 Prague 71, Czech Republic	
		ČSN EN 50626- 1:2024	Internal Test Report No. 164/2026 of 21.07.2026	06058/2 TP-KO 02-05
			Documents for designing plastic cable ducts, Brno 2012, order no. 120111 Issued by: EGÚ Brno, a.s. Electrical Network Department	
Regulation 1907/2006 - REACH				Safety data sheets for used materials

By fulfilling the conditions in accordance with these regulations was placed on the product CE marking

Conformity assessment module: **MODUL A: Internal production control**

Technical documentation of products:

- assembly instructions
- Datasheet
- Catalog for products freely available on <http://www.kopos.com/en/catalogue>
- Internal documents

KOPOS KOLÍN a.s. company is certificated according to the standard ISO 9001:2015, ISO 14001:2015 and ISO 50001:2018 according to the National program „Safety Enterprise“.

Signed on behalf of KOPOS KOLÍN a.s.



Ing. Jana Dejmková

Quality and ecology director

Place of issue: Kolín, Czech Republic

Date of issue: 22.07.2026